



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 3

**General Comments**

Group Inspection:  
Idaniel Gonzalez (Principal).  
Jennifer Gonzalez (Assistant Principal).  
Mayra S. Gutierrez (Head Custodian), assisted with inspection.  
Mirelis Soca (Secretary), signed the inspection.  
No shower(s) on campus (N/A).

Email Address(es): idaniel@dadeschools.net;  
jengonzalez@dadeschools.net;  
ipalacio@dadeschools.net;  
wcabrera@dadeschools.net;  
mwertz@dadeschools.net;

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



3 of 3

### Violations Comments

#### Violation #5. Maintenance & Repair

##### Observations:

##### Stains on Ceiling' Panel(s):

1. Room # 077 (one (1) stained ceiling' panel by ENTRANCE' right side).
2. Room # 046 (three (3) stained ceiling' panels).

Replace all stained ceiling' panels.

##### Dust/Dirt on HVAC Exhaust Ventilation System:

1. Room # 046 (dust/dirt on one (1) exhaust ventilation system).
- Clean one (1) exhaust ventilation system in Room # 046.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

#### Violation #6. Lighting Standards

##### Observations:

##### Burnt-Out Light' Bulb(s) in Lamps:

1. Room # 019 (one (1) burnt-out light' bulb in one (1) Lamp: FC: 36.0).
2. Room # 077 (one (1) Lamp with three (3) burnt-out light bulbs: FC: 26.3).
3. Room # 063 (one (1) Lamp with one (1) burnt-out light' bulb: FC: 51.1).

Replace all burnt-out light' bulbs in each Lamp.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Alberto Reyes (032763)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name: Mirelis Soca (Secretary)  
Date: 6/10/2024

Inspector Signature:

Handwritten signature of Alberto Reyes.

Client Signature:

Handwritten signature of Mirelis Soca.